

# Electro Steam Thermal Complex Powered by Wind-Driven Generator for the Treatment of the Oil Formation's Bottomhole Area

A A Belsky, V S Dobush and V I Malarev

Saint-Petersburg Mining University, Vasilevsky Island, 21th Line, 2, Saint-Petersburg, 199106, Russia

E-mail: Belskij\_AA@pers.spmi.ru

**Abstract.** In this article authors propose application of the wind-driven power units as power source of bottomhole electric steam generator for the thermal high-viscosity oil reservoir stimulation. The structure of the electro steam thermal complex is proposed. An analysis of the wind energy potential in the areas where the largest high-viscosity oil deposits in Russia are located is carried out. As part of the complex under consideration, the type of the dependence of the bottomhole electric steam generator's power on the formation depth has been established. The calculation of the required installed capacity of wind power plants for placement as part of the electro steam thermal complex at the largest high-viscosity oil deposits in Russia has been performed.

## 1. Introduction

Due to the exhaustion of low-density oil deposits, heavy and high-viscosity oil (HVO) production increases in Russia, as well as around the world. For its efficient extraction, various thermal methods are used to increase oil recovery. For instance, technology of steam injection into the oil reservoir is particularly common.

In land-based steam generating plants, energy from the combustion of natural gas, oil-well gas, a portion of previously produced oil, or diesel fuel is consumed to produce water steam. Then, using pumps, steam is injected through heat-insulated oil well tubing (OWT) into the oil reservoir. Owing to the steam-heat stimulation, the viscosity of the oil decreases and its production is carried out. However, with an increase in the depth of the HVO formation, the heat losses in the OWT increase, as a result, the steam cools and condenses. It leads to a decrease in the efficiency of the steam-heat stimulation, and oil production becomes unprofitable. Therefore, this technology has a limit on the depth of the oil reservoir, usually not more than 1000 m [1–3].

More than half of the Russian HVO deposits are located in the Arctic region [4]. At the same time, the use of traditional technology of steam-heat stimulation of oil deposits using land-based steam generating plants can lead to thawing of permafrost rocks around the wells. As a result, the risk of deformation of the wellbore, subsidence of the wellhead and equipment damage increases [5–7].

It is possible to increase the efficiency of the thermal effect on the HVO, especially at a depth of more than 1000 m, by using electro steam thermal complex where thermal energy (steam) is generated directly in the bottomhole zone of the well. Owing to this, energy losses are reduced both at the stage of steam production and during its delivery to the formation. The use of bottomhole electro steam



thermal complexes will also reduce the possibility of permafrost thawing as the main thermal processes take place below its depth. The bottomhole electric steam generators of various capacities have been developed [8, 9] at Saint Petersburg Mining University. It can be used for both HVO production and for controlling paraffin deposits in oil wells [10, 11]. However, a source of external power supply with a capacity of over 300–500 kW is required [12] for the implementation of this technology.

Most HVO deposits are located in regions that are either poorly covered by a centralized power supply system, or where the connection of power generating complexes is difficult due to the lack of a sufficient power reserve and transmission capacity of existing power lines. These circumstances impede the introduction of steam thermal complexes with bottomhole electric steam generator for efficient production of HVO.

The purpose of this research is to study issues related to determining the required installed capacity of a wind-driven generator (WDG) used as an autonomous power source for a steam-thermal complex with bottomhole electric steam generator.

## 2. The structure of the complex

A wind-driven generator is designed to power the bottomhole electric steam generator and auxiliary equipment (electric pump, control system, etc.). In the absence of wind, the steam generation process stops and then resumes when the wind speed exceeds the minimum operating value (usually 3 m/s).

The complex works as follows (Figure 1): WDG (1) produces a three-phase electric current of variable frequency and variable voltage level depending on the current wind speed. Further, through the rectifier (2), the current flows to the DC/DC converter (3), where the voltage level on the DC bus is stabilized. Single-phase autonomous inverter (4) with high-voltage (3–10 kV) single-phase power transformer (5) for supplying bottomhole electric steam generator (15) connects to a DC bus as well as a three-phase autonomous inverter (6) for powering a variable speed drive (7) of a pump (8) and auxiliary equipment, including a control system (9). When voltage is applied, the current from the power transformer (5) pass through the armored cable (10) through the input device (11) and then through the tubular insulated current lead (13) to the central electrode (14) of the bottomhole electric steam generator (15). Inside the steam generator, current flows from the central current lead through the perforated electrodes through the conductive fluid (18) to the housing electrodes, generating the required power. The automatic maintenance of the set technological parameters (boiler water consumption, pump speed) is provided by the control system (9).

The main structural parameters of the bottomhole electric steam generator (length, outer diameter) are determined by the diameter of the casing string and the productive formation thickness as well as the required thermal output [13, 14].

Electro steam thermal complex powered by wind-driven generator for the treatment of the oil formation's bottomhole area includes (Figure 1): 1 – wind-driven generator; 2 – three-phase rectifier; 3 – DC/DC converter with a DC bus; 4 – single-phase self-excited inverter; 5 – high-voltage (3...10 kV) single-phase supply transformer; 6 – three-phase self-excited inverter; 7 – adjustable speed drive; 8 – pump; 9 – control system; 10 – power cable; 11 – oil-filled input device; 12 – dielectric insert; 13 – tubular busduct; 14 – central current conductor; 15 – frame of the bottomhole electric steam generator; 16 – heat-resistant packer; 17 – water supply unit with a backpressure valve; 18 – formation fluid; 19 – casing string; 20 – boiler water; 21 – tubing.



**Table 1.** The largest HVO deposits in Russia [4].

Deposit (region)	Occurrence depth (m)	The average annual wind speed (m/s)
<i>West Siberian Petroleum Bearing Province</i>		
Russkoe (Tazovsky District <sup>a</sup> )	664	7.0
Severo-Komsomolskoe (Nadym and Purovsky Districts <sup>a</sup> )	1056	6.5
Van-Yeganskoe (Nizhnevartovsk District <sup>b</sup> )	893...1330	5.0
Tazovskoe (Tazovsky District <sup>a</sup> )	1076	7.0
Novoportovskoe (Yamal District <sup>a</sup> )	900	7.5
Zapadno-Messoyakhskoe (Tazovsky District <sup>a</sup> )	834	7.0
<i>Volga-Ural Petroleum Bearing Province</i>		
Romashkinskoe (Almetyevsk District <sup>c</sup> )	750	6.0
Novoelkhovskoe (Almetyevsk and Zainsky Districts <sup>c</sup> )	760...1100	6.0
Akanskoe (Nurlat District <sup>c</sup> )	1036	5.0
Nurlatskoe (Oktyabrsky District <sup>c</sup> )	858...1940	6.0
Stepnoozerskoe (Nurlat District <sup>c</sup> )	1345	5.0
Aksubaevo-Mokshinskoe (Aksubaevsky District <sup>c</sup> )	927	5.5
Gremikhinskoe (Votkinsk District <sup>d</sup> )	1110...1345	5.0
Chuboyskoe (Balezinsky District <sup>d</sup> )	2025	6.0
Mishkinskoe (Votkinsk and Sharkan Districts <sup>d</sup> )	1425...1490	5.5
Zimmitskoe (Cherdaklinsky District <sup>e</sup> )	1325	5.0
<i>Timan-Pechora Petroleum Bearing Province</i>		
Usinskoe (Usinsky District <sup>f</sup> )	1260	6.0
Yaregskoe (Ukhta District <sup>f</sup> )	130...175	6.0
Srednemakarihinskoe (Usinsky District <sup>f</sup> )	1796	6.0
Naulskoe (Zapolyarny District <sup>g</sup> )	850...890	7.0
Toraveiskoe (Zapolyarny District <sup>g</sup> )	970...1515	7.0
Varandeyskoe (Zapolyarny District <sup>g</sup> )	1290...1625	7.0
Labaganskoe (Zapolyarny District <sup>g</sup> )	1400	7.0
Zapadno-Lekkeyyaginskoe (Zapolyarny District <sup>g</sup> )	1364	7.0
Toboysko-Myadseyskoe (Zapolyarny District <sup>g</sup> )	2750	7.0
Yuzhno Toraveiskoe (Pechora District <sup>f</sup> )	1060	6.0
<sup>a</sup> Yamalo-Nenets Autonomous District	<sup>e</sup> Ulyanovsk region	
<sup>b</sup> Khanty-Mansiysk Autonomous District	<sup>f</sup> Komi Republic	
<sup>c</sup> Republic of Tatarstan	<sup>g</sup> Nenets Autonomous District	
<sup>d</sup> Republic of Udmurtia		

Most HVO deposits have a high wind energy potential (average annual wind speed of at least 6 m/s), with the exception of the Van-Yeganskoe, Akanskoe, Stepnoozerskoe, Gremikhinskoe, Zimmitskoe deposits (average annual wind speed about 5 m/s).

#### 4. Heat calculation


The power allocated in the bottomhole electric steam generator is spent on heating the working fluid and its evaporation, taking into account the dependence of the environmental parameters and the properties of the working fluid on the depth at which the steam and thermal effect on the bottomhole zone of the oil reservoir is carried out:

$$W = Q \cdot (T_s(P(h)) - T_0) \cdot c_w(T(h), P(h)) \cdot \rho_w(T(h), P(h)) + Q \cdot r_w(T(h), P(h)) \cdot \rho_w(T(h), P(h)),$$

where  $Q$  – volumetric flow rate of the power fluid ( $\text{m}^3/\text{s}$ );  $P$  – steam pressure (Pa);  $T_s$  – boiling point ( $^{\circ}\text{C}$ );  $T_0$  – wellhead temperature ( $^{\circ}\text{C}$ );  $c_w$  – specific heat capacitance of the power fluid ( $\text{J}/(\text{kg}\cdot^{\circ}\text{C})$ );  $\rho_w$  – the power fluid density ( $\text{kg}/\text{m}^3$ );  $r_w$  – the power fluid heat of evaporation ( $\text{J}/\text{kg}$ ).

The temperature at the wellhead ( $T_0$ ) is taken equal to  $20^{\circ}\text{C}$ , the pressure during vaporization ( $P$ ) formed by a liquid column ( $h$ ) in the OWT. Boiler water is used as the power fluid, in which the specific heat, density and heat of evaporation depend on temperature and pressure and are determined taking into account the thermophysical properties of water and water vapor according to the reference data [16].

The result of calculating the dependence of the bottomhole electric steam generator power on the depth of the formation to produce 12 tons of steam per day (the minimum recommended daily volume of steam for thermal impact on the HVO) is shown in Figure 2.



**Figure 2.** Dependence of bottomhole electric steam generator power (W) on the depth of the formation (h) for producing 12 tons of steam per day.

## 5. WDG power selection

For power supply of bottomhole electric steam generator it is supposed to use WPG with 200...400 kW nominal capacitance at a nominal wind speed of 12 m/s. The power of a wind wheel (rotational speed) is limiting by turning a blade; more than 50 m high mast is sectionalized and held by several levels of stretch marks, for example, WDG Vergnet GEV MP C 200–275 kW. This design of WDG allows installation work without the involvement of crane equipment. This is especially important for remote and hard to reach places.

Taking into account the above technical data of the wind turbine and the average annual wind speeds, the estimated variation range of the plant utilization factor (PUF) of WDG is presented in table 2 [17, 18].

**Table 2.** PUF of WDG.


Average annual wind speed (m/s)	PUF (%)	Average annual wind speed (m/s)	PUF (%)
5.0	19–26	6.5	33–35
5.5	24–29	7.0	34–39
6.0	29–31	7.5	40–43

To ensure an average level of steam generation of 12 tons per day, the required wind turbine power will be determined by the formula:

$$W_{WG} = 1.2 \cdot \frac{W(h)}{k} \cdot 100\%,$$

where  $W_{WG}$  – WDG installed capacitance (kW);  $W(h)$  – design capacitance of bottomhole electric steam generator to produce 12 tons of steam per day (kW);  $k$  – PUF of WDG (%); 1.2 – safety factor taking into account losses in cable lines, converting equipment and a transformer, as well as the own needs of the energy complex.

We will calculate the required installed capacitance of WDG (Figure 3) for power supply to the bottomhole electric steam generator with an average productivity of 12 tons of steam per day for the wells of the largest HVO deposits in Russia. In this case, we will use the average occurrence depth of oil formation for each field (table 1) and the average PUF for each average annual wind speed (table 2).



**Figure 3.** Required installed WDG capacity for powering the bottomhole electric steam generator with a capacity of 12 tons of steam per day.

## 6. Conclusion

It is most effective to use WDG to power the electro steam thermal complex to reduce oil viscosity in the following fields: Toboysko-Myadseyskoe, Varandeyskoe, Labaganskoe, Zapadno-Lekkeyyaginskoe in the Zapolyarny district of the Nenets Autonomous District; Novoportovskoye and Tazovsky in the Yamal and Tazovsky District of the Yamalo-Nenets Autonomous District; Chubovskoe in the Balezinsky District of the Republic of Udmurtia.

For these fields, the installed capacity of wind turbines will not exceed 1200 kW to ensure an average daily volume of steam generation at the level of 12 tons.

## Acknowledgments

The reported study was funded by RFBR according to the research project №18-38-00530.

## References

- [1] Zyrin V and Ilinova A 2016 Ecology safety technologies of unconventional oil reserves recovery for sustainable oil and gas industry development *J. of Ecological Engineering* **17** (4) pp 35–40
- [2] Alvarado V and Manrique E 2010 Enhanced oil recovery: an update review *Energies* **3** pp 1529–75

- [3] Nikolaev N I and Tianli Lu 2016 The modern technology of drilling and casing of well during the exploration of gas hydrates *J. of Mining Inst.* **218** pp 206–14
- [4] Makarevich V N, Iskritskaya N I and Bogoslovsky S A 2012 Resource potential of heavy oils fields in European Russian *Petroleum Geology - Theoretical and Applied Studies* **7** 3 43
- [5] Gorelik J B, Soldatov P V and Seleznev A A 2015 Engineering and geocriological conditions of the yamburg gas and condensate reservoir and dynamics of the ground state of boreholes *Earth's Cryosphere* **19** 1 pp 58–69
- [6] Gorelik J B and Soldatov P V 2016 Loss of axial stability of casing in permafrost production wells with a lateral support on thawing ice rich ground *Earth's Cryosphere* **20** 4 pp 93–104
- [7] Korolev N, Zhukovskiy Y and Koteleva N 2018 About increasing informativity of diagnostic system of asynchronous electric motor by extracting additional information from values of consumed current parameter *J. of Physics: Conference Series* **1015** 032158
- [8] Zyrin V 2018 Electrothermal complex for heavy oil recovery: Analysis of operating parameters *Int. J. of Mechanical Engineering and Technology* **9** 11 pp 1952–61
- [9] Zagrivniy E A, Malarev V I, Lakota O B and Zyrin V O 2012 Downhole electrosteam generator-separator *RU patent* 2451158
- [10] Kopteva A V and Koptev V Y 2018 Automatic measuring system for oil stream paraffin deposits parameters *IOP Conf. Series: Materials Science and Engineering* **327** 042053
- [11] Kopteva A V and Malarev V I 2018 Studying thermal dynamic processes in an isolated type borehole electrode heater for high-viscosity oil extraction *Proc. of the IEEE Conf. of Russian Young Researchers in Electrical and Electronic Engineering* pp 678–81
- [12] Pirog S, Shklyarskiy Ya E and Skamyin A N 2019 Non-linear electrical load location identification *J. of Mining Inst.* **237** pp 317–21
- [13] Tatevosyan A S, Tatevosyan A A, Zakharova N V and Lukacheva A A 2018 Determination of equivalent circuit parameters of the electric pulse device for cleaning the surface from contamination *12th Int. Scientific and Technical Conf. Dynamics of Systems, Mechanisms and Machines* 8601435
- [14] Zagrivnyi E A, Malarev V I and Kopteva A V 2019 Studying the operating mode of the down-hole electrode heater for the production of high-viscosity oil *Proc. of the IEEE Conf. of Russian Young Researchers in Electrical and Electronic Engineering* pp 1–4
- [15] Krasnoyarova N A, Yashchenko I G and Serebrennikova O V 2015 Area and cross-section distribution of viscous waxy oils in deposits located in the southeast of Western Siberia. *Bulletin of the Tomsk Polytechnic University Geo Assets Engineering* **326** 2 pp 70–9
- [16] Alexandrov A A and Grigoriev B A 1999 Tables of thermophysical properties of water and water vapor *Handbook (MEI)* p 164
- [17] Belsky A A 2013 Evaluation of a wind power plant parameters for the efficiency of energy exploration work *Gornoye oborudovaniye i elektromekhanika* **6** pp 7–13
- [18] Astapov V and Palu I 2017 Operation and stability analysis for standalone microgrid through simulations in DigSilent software *Proc. of the 18th Int. Scientific Conf. on Electric Power Engineering* pp 1–6